

**PRV INSPECTION AND TEST REPORT**

BRANCH: Fort St John

UVL ID#: 17643F

Work Order: 307075

Customer PO#: N/A

Customer: CANADIAN NATURAL RESOURCES LIMITED

Date: 3/29/2011

Facility: BEG

LSD: a-03-K/94-G-01

PSV Location: DEHY

A#: A602749

Vessel SN: 2009-8009-01

Cust Id: N/A

Cust. Ref.: N/A

Valve PO: N/A

PO Line#: N/A

Cust WO#: N/A

Cust AFE#: N/A

Cost Centre #: 80005694

VALVE DATA

Man.: MERCER

Model: 91-17E51T17NX1

Serial: C006550

Seat: Soft

Conn: Threaded

Inlet: 1" MNPT

Orifice: E

Outlet: 1" FNPT

Set Pres: 1350 PSI

Back Press: 0 PSI

Cold/Diff Set: PSI

Temp: 70°F

Cap: 4767 SCFM

Lift Lever: ☐

Cap Assembly: Closed

Code Symbol: UV

CRN#: 0G8841.5C

CUSTOMER INSTRUCTIONS

Instructions: Pretest, Service if Required

Pretest Required? ☐Reset Required? ☐

Replaces UVL ID#:

Replaces Serial #:

Replaces Cust ID#:

RESET INFO: New Pressure:

New Cold/Diff:

New Capacity:

New Model:

CONDITION AS RECEIVED

Visual Condition: Good

Data Plate Condition: OK

Date of last service: DOM 01/11

Seal Condition: Top: Intact

Bottom: N/A

Insignia: MVC

Fittings Attached: Inlet: ☐ Outlet: ☐

Inlet: Clean

Inlet Plugged: ☐

Outlet: Clean

Outlet Plugged: ☐

Initial Insp. Signoff: Grant Watson

PRETEST 1

Simmer: 1323 PSI Set Press:

1325 PSI Reseat:

1210 PSI

Leakage:

0 BPM Test gauge: FSJ 1+2

Tested by: Harley Anderson

Pretest comments:

PRETEST 2

Simmer: PSI Set Press:

PSI Reseat:

PSI

Leakage:

BPM Test gauge:

Tested by:

Pretest comments:

ITEM	CLEAN OILY RUSTY CARBON OTHER COMMENTS					OK / REPLACE		REPLACED? REPAIRS PERFORMED	
0									
DISC	☐	☐	☐	☐	☐			☐	
NOZZLE	☐	☐	☐	☐	☐			☐	
CAP-LEVER ASSY	☐	☐	☐	☐	☐			☐	
COMP SCREW and LOCKNUT	☐	☐	☐	☐	☐			☐	
SPRING and BUTTONS	☐	☐	☐	☐	☐			☐	
SPINDLE / STEM	☐	☐	☐	☐	☐			☐	
STEM RETAINER	☐	☐	☐	☐	☐			☐	
DISC HOLDER	☐	☐	☐	☐	☐			☐	
GUIDE / UPPER RING	☐	☐	☐	☐	☐			☐	
LOWER RING	☐	☐	☐	☐	☐			☐	
RING PIN(S)	☐	☐	☐	☐	☐			☐	
BELLOWS	☐	☐	☐	☐	☐			☐	
GASKET / SEALS	☐	☐	☐	☐	☐			☐	
CONNECTION ENDS	☐	☐	☐	☐	☐			☐	
OTHER	☐	☐	☐	☐	☐			☐	

Disc: MIN=

ACT=

Nozzle: :

ACT=

Spring Number:

Comments:

Disassembly:

Inspection:

Reassembly:

FINAL TEST:

Test Medium: Air

Simmer: 1349 PSI

Set Pressure:

1350 PSI

Reseat: 1255 PSI

Leakage Acceptable as per API 527.: ☒

B.P. Test:

60 PSI

ADJ. RING SETTING (NOTCHES): Upper: N/A

Lower: N/A

Test Gauge FSJ 1+2

Set Press Def: POP

Tested by: Harley Anderson/GRANT WATSON

FINAL INSPECTION:SEAL: Top: ☒ Bottom: ☐ End Protectors Installed: ☒ Painted: ☒ Palletized: ☐ Ship Container: ☒ Flex Gaskets Supplied: ☐

Final Inspection: Grant Watson

Customer Inspection

Comments: