

**Canadian Natural Resources Limited
GENERAL PRESSURE VESSEL INFORMATION**

Job # 10.111452

| | | | | | | |
|---|-------------------|---------------------------------------|------------------------------|-----------------------|--------------------|-----------------|
| District: Grande Prairie AB | | Skid No. | | | | |
| Facility: Spring Lake Gas Gathering | | Location (LSD): 06-13-76-12W6M | | | | |
| Vessel Name Equipment Number: 3 Phase Separator | | | | | | |
| Orientation: Vertical | | | | | | |
| Status: In Service | | | Regulatory Inspection | | | |
| PRESSURE VESSEL NAMEPLATE DATA | | | | | | |
| “A” or “G” or “S” (Sask.) or BC Registration Number. A0490281 | | | CRN Number: L 8388.2 | | | |
| Vessel serial number: C1829A-VS | | | Size: 20 in. X 96 in. | | | |
| Shell thickness: 22.2 mm | | | Shell material: SA 516-70N | | | |
| Head thickness: 23.8 mm | | | Head material: SA 516-70N | | | |
| Tube wall thickness: | | | Tube material: | | | |
| Tube diameter: | | | Tube length: | | | |
| Channel thickness: | | | Channel material: | | | |
| Design pressure | Shell: 1440 PSI | | Operating pressure | Shell: 0 – 1500 PSI | | |
| | Tubes: | | | Tubes: | | |
| Design Temp. | Shell: 129 Deg F. | | Operating temperature | Shell: 0 – 250 Deg F. | | |
| | Tubes: | | | Tubes: | | |
| X-ray: RT 1 | | | Heat treatment: HT | | | |
| Code parameters: ASME VIII, Div 1 | | | Coated: no | | | |
| Manufacturer: Rushton | | | Year built: 2002 | | | |
| Corrosion allowance: 3.2 mm | | | Manway: no | | | |
| PRESSURE SAFETY VALVE NAMEPLATE DATA | | | | | | |
| PSV Tag # | Manufacture | Model # | Serial # | Set Pressure (kPa) | Capacity (scfm) | Service Date |
| | Mercer | 8100-1M | 133143 | 1422 PSI | 4991 | 08, 2008 |
| CRN # | Service By | Block Valve | Location | Size | Code Stamp | |
| OG8841.5C | IPV | no | Upper shell | 1”x 1” | UV/NB | |
| SERVICE CONDITIONS-INDICATE ALL THAT APPLY | | | | | | |
| Sweet | Sour X | Oil | | Gas X | Water X | |
| Amine | LPG | Condensate X | | Air | Glycol | |
| Other (Describe): | | | | | | |

Inspection Interval _____ **PSV Service Interval** _____
 (Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL Owner-User Inspection Program)

Reports reviewed and accepted by:
Mechanical Integrity Coordinator _____ **Date** _____


Fill out all forms as completely as possible. All information is important! Use back of sheets to record additional information or sketch if required.
 Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

| External Inspection Items | G | F | P | N/A | Comments |
|---|---|---|---|-----|--|
| Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture. | | | | X | Vessel not insulated. |
| External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage) | X | | | | Paint in good overall condition – No exposed metal. |
| Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc. | X | | | | No leaks observed. |
| Saddle/Skirt Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached? | X | | | | Skirt: bolted directly to skid floor. No buckling or dents. No corrosion at attachment welds to vessel. Ground wire attached to skid. |
| Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation. | X | | | | Anchor bolts are securely fastened. No deformation. |
| Concrete foundation Check for cracks, spalling, etc. | | | | X | |
| Ladder / Platform Describe general condition, ensure support is secure to vessel, describe any hazards. | | | | X | |
| Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted? | X | | | | Stud threads are fully engaged to nuts – no short bolts. No damage or deflections – no leaks. Nozzles are not gusseted. |
| Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp. | X | | | | Clear and clean – no leakage. Within operational range for service – pressure gauge 0 – 1500 PSI/temperature gauge 0 – 250 Deg F. |
| External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion? | X | | | | Piping is well supported; no deflection, all clamps and supports are in place. Paint in good condition – no exposed metal. |
| Valve: Ensure no leaks are visible. Valves are properly supported and chained if necessary. | X | | | | Valves are supported properly – no leaks. |
| PSV Ensure PSV is set at pressure at or below that of vessel. | X | | | | Location: On upper shell- Set below MAWP of vessel. No block valve between vessel and PSV. Discharge piping is same size as valve out let. Seal in place. |
| NDE methods Was UT/ MPI done on vessel (MI coordinator to review results) | X | | | | Ultrasonic thickness survey carried out – no metal thickness detected below nominal minus corrosion allowance. |
| Other | | | | | |
| Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented) Recommendations: No recommendations. Summary: Vessel is in overall good condition, visual external inspection and ultrasonic corrosion survey performed – no metal thickness detected below nominal minus corrosion allowance. Long term corrosion rate based on greatest thickness loss (head) 0.170mm per year. Retirement Date to “T”min is year 2043. Vessel is fit for service. | | | | | |

Photo Table



LSD




Vessel data plate



Pressure gauge



Temperature gauge



PSV data plate



PSV data tag



PSV



Vessel overview